



Water use in engineering dormitory in Greenland - Apisseq Sisimiut - Greenland

Kotol, Martin

Publication date:
2012

Document Version
Early version, also known as pre-print

[Link back to DTU Orbit](#)

Citation (APA):
Kotol, M. (2012). *Water use in engineering dormitory in Greenland - Apisseq: Sisimiut - Greenland*. DTU Byg, Danmarks Tekniske Universitet. Byg Rapport No. R 278

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Water Use in Engineering Dormitory APISSEQ Sisimiut - Greenland



BYG R 278
BYG·DTU
November 2012
ISBN: 9788778773630

Water Use in Engineering Dormitory

APISSEQ

Sisimiut - Greenland

Author:

Martin Kotol

Preface

The report contains information about the annual water use in the engineering dormitory Apisseq. The report begins with brief description of the dormitory and then presents the water use, its fractions (cold water and DHW) and also the energy use related to DHW heating. Significant portion of the energy is covered by the solar plant.

November 2012
Technical University of Denmark

1 Introduction

In summer 2010 the new dormitory Apisseq was finished in Sisimiut, Greenland. The intention was to build an energy efficient building in which the modern technologies, not yet commonly used in the Arctic, could be installed and tested. The aim of the technologies has been to minimize the energy consumption and provide the occupants of the building with healthy and comfortable indoor environment.

The building was equipped with a complex monitoring system (Vladyková et al. 2010) which will document the performance of the whole building as well as of some individual systems over their lifetime.

The Domestic Hot Water (DHW) is first preheated by the hot water from accumulation tanks heated by solar collectors on the roof. The rest of the heat is delivered by district heating. The circulation losses are covered purely by district heating.

The entire water use in the building relates to its occupants and their activities such as cooking, drinking showering, toilet flushing or doing laundry.

For purpose of this report one year period from 1st November 2011 to 31st October 2012 was considered.

1.1 Key numbers

1414	m ²	Heated floor area
41	pers.	Occupancy (this number varies over the season)
38	pcs	Evacuated solar collectors
4	m ³	Accumulation tanks total capacity

2 Water use

The annual water use was 1581 m³ out of which 816 m³ (51.6 %) was used for DHW. It can be seen in Figure 1 that the lower occupancy during the summer months has a significant effect on water use. The average water use per occupant when June and July neglected was 115 l/(pers·day) out of which 61 l/(pers·day) was DHW at the average temperature 54.4 °C. The temperature of the cold water was in average 5.5 °C and the monthly averages can be found in the Figure 1.




Figure 1 Water use and cold water temperature

3 Energy use

The amount of energy related to DHW heating was 51,145.4 kWh out of which 41% (20,896.0 kWh) was covered by solar heating. The rest (30,617.7 kWh) was covered by district heating. The electricity for the circulation pumps as well as for the frost protection of the outside pipeline was not measured during this period. This will further increase the total energy use related to DHW.




Figure 2 Energy use related to DHW

4 Conclusion

The amount of energy from district heating used for DHW was as high as **30,617.7 kWh** which is 10.1 % of the annual heat demand of the entire building (303,600.0 kWh). Partial savings can be achieved by the following actions:

- Installing the low flow shower heads
- Adjusting the solar system for better performance
- Installing the waste water heat recovery
- Heating the circulation water by solar energy when available

References

Vladyková, P., Kotol, M., Vladyková, P. & Kotol, M. 2010, Monitoring system in new dormitory APISSEQ, Sisimiut, Greenland, DTU Byg.